

To,

The Executive Engineer,
Provincial Division No.1
PWD (B&R) Br., Ambala Cantt.

Memo No.

210

Dated: 05.03.2026

Subject: Structural safety certificate for S.A Jain Senior Model School, Ambala City.

Ref: - Your office endst no.914 dated. 03.02.2026.

The School Building i.e. S.A Jain Senior Model School, Circular Road, Ambala City was visually inspected by undersigned alongwith J.E. in-charge. The building is inspected visually and found safe for running School. Hence, the school building safety certificate for the year 2026-27 may be issued with following conditions:-

1. Building of this school should be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the building.
3. If building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. Institution will be responsible for safety of building from every angle and Fire-fighting Equipment should be in functional condition.
5. The processing fees of Rs 5000/- already stands deposited by the School Authority vide Demand Draft No. 002189 dated 06.02.2026.
6. If the building of the school is to be extended, the same should be first approved from Structural Engineer.
7. Institution shall also ensure safety precautions from false ceiling and vitrified used in dado.
8. NOC may be considered as cancelled by his office if the school violates any of the above points.

This is for your kind information and further necessary action please.

DA/Photographes


Sub Divisional Engineer,
Provincial Sub Division No -7,
PWD (B&R) Br, Ambala Cantt.